AMPROBE®



Data Sheet

MO-100 Milliohm Meter

Diagnose potential failure with the MO-100, portable battery powered Milliohm Meter. Quickly check windings opens or shorts in motors, generators and transformers, wire-to-wire connection resistances, heating elements testing and contact resistance in critical electrical connections.

- Accurate four terminal measurement down to 100µ ohms does not require test leads resistance compensation
- 5 Ranges from 200.0m ohms to 2000 ohms with minimum resolution of 100µ Ohm
- Measurement precision with three test currents with over-temperature protection
- Protection against inadvertent connection to overvoltage
- Large LCD
- Potential lead resistance, current lead resistance checks
- AUTO-HOLD and AUTO-OFF features
- Lightweight, robust & compact.
- Indicates measurement errors due to temperature or connection problems
- "O-Ring" sealed enclosure
- **■** Battery powered
- IEC / EN 61010-1

No hassle warranty

No waiting.





(note: \$500 MSLP limit)



MO-100 Milliohm Meter

Data Sheet

Specifications

- p	
Measuring Ranges	0-200.0m ohms in steps of 100μohm
	0-2000m ohms in steps of 1m ohm
	0-20.00 ohms in steps of 10m ohm
	0-200.0 ohms in steps of 100m ohm
	0-2000 ohms in steps of 1 ohm
Accuracy	±0.5% of reading ±2 digits over the operating temperature range, -15°C to 55°C (5°F to 131°F),
	with the supplied test leads
Test Current	1mA =>2000 ohms range
	10mA =>200/ 20 ohms ranges
	100mA =>2000m / 200m ohm ranges
Accuracy	±0.1%
Protection Fuses	Mains = 0.5A, HBC, 5 x 20mm, DIN
	Current = 0.5A, HBC, 5 x 20mm, DIN
	Voltage = 0.5A, HBC, 5 x 20mm, DIN
	Maximum Output
	Voltage (C1-C2) 20V
Dimensions	250(L) x 190(W) x 110(D)mm (9.8 x 7.5 x 4.3 in)
Weight	1500 g (3.3 lb)
Accessories	Test leads, Instruction manual, Shoulder belt, 1.5V(AA) x 8 Batteries

Amprobe® Test Tools

website: www.Amprobe.com email: info@amprobe.com

Everett, WA 98203 Tel: 877-AMPROBE

Amprobe® Test Tools Europe

In den Engematten 14 79286 Glottertal, Germany Tel.: +49 (0) 7684 8009 - 0

©2009 Amprobe Test Tools. All rights reserved. 7/2009 3520387 Rev A